

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CP0214Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	BERETTA Via Risorgimento, 13, I-23900 Lecco (LC)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	condensing boiler
Model <i>Modell</i>	Power Max...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	type testing: B 17/08/2424 EU from 28.12.2017 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	20-0722-GWU

70028-04-A-DE

16.11.2020 Rie G-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.


DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Energy Labelling <i>Energieeffizienzkennzeichnung</i>
Power Max 50 P DEP	nominal heat output: 8,9...34,4 kW heat input (Hi): 9,0...34,9 kW	
Power Max 50 P	nominal heat output: 8,9...44,2 kW heat input (Hi): 9,0...45,0 kW	
Power Max 65 P	nominal heat output: 13,5...55,7 kW heat input (Hi): 14,0...57,0 kW	
Power Max 80 P	nominal heat output: 13,5...67,0 kW heat input (Hi): 14,0...68,0 kW	
Power Max 100	nominal heat output: 19,2...88,3 kW heat input (Hi): 19,4...90,0 kW	
Power Max 110	nominal heat output: 19,2...95,3 kW heat input (Hi): 19,4...97,0 kW	
Power Max 130	nominal heat output: 22,1...109,8 kW heat input (Hi): 22,4...112,0 kW	
Power Max 150	nominal heat output: 26,0...129,0 kW heat input (Hi): 26,2...131,0 kW	

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CP0214**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	BERETTA Via Risorgimento, 13, I-23900 Lecco (LC)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	condensing boiler
Model <i>Modell</i>	Power Max...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: B 19/05/3009 EU from 04.10.2019 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

Date of Expiry / File No. 10.04.2028 / 20-0722-GEU
Ablaufdatum / AZ16.11.2020 Rie G-1/2 Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation EU/2016/426.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Appliance Categories <i>Gerätekatégorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I3+	28-30/37 mbar	BE	
I3B/P	30 mbar	CY, IS, MT	
II2E+3+	20/25, 28-30/37 mbar	FR	
II2E3B/P	20, 37 mbar	PL	
II2E3P	20, 37 mbar	LU	
II2ELL3B/P	20, 50 mbar	DE	
II2ELwLs3B/P	20,20,13, 37 mbar	PL	
II2Esi3+	20/25, 28-30/37 mbar	FR	
II2Esi3B/P	20/25, 28-30 mbar	FR	
II2H3+	18, 28-30/37 mbar	ES	
II2H3+	20, 28-30/37 mbar	GB, GR, IE, SI, SK	
II2H3+	20, 30/37 mbar	IT, PT	
II2H3B/P	20, 28-30 mbar	HR	
II2H3B/P	20, 30 mbar	DK, EE, FI, IE, LT, LV, NO, RO, SE, SI, SK	
II2H3B/P	20, 50 mbar	AT, CH, CZ, LU, SK	
II2H3B/P	25, 30 mbar	HU	
II2H3P	20, 37 mbar	SI, SK	
II2L3B/P	25, 30 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Power Max 50 P DEP	nominal heat output: 8,9...34,4 kW heat input (Hi): 9,0...34,9 kW	
Power Max 50 P	nominal heat output: 8,9...44,2 kW heat input (Hi): 9,0...45,0 kW	
Power Max 65 P	nominal heat output: 13,5...55,7 kW heat input (Hi): 14,0...57,0 kW	
Power Max 80 P	nominal heat output: 13,5...67,0 kW heat input (Hi): 14,0...68,0 kW	
Power Max 100	nominal heat output: 19,2...88,3 kW heat input (Hi): 19,4...90,0 kW	
Power Max 110	nominal heat output: 19,2...95,3 kW heat input (Hi): 19,4...97,0 kW	
Power Max 130	nominal heat output: 22,1...109,8 kW heat input (Hi): 22,4...112,0 kW	
Power Max 150	nominal heat output: 26,0...129,0 kW heat input (Hi): 26,2...131,0 kW	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
Power Max	wall hanging appliance

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Electrical data: 230 V AC, 50 Hz

additional countries of destination/ appliance categories: TR and BG: II2H3B/P: 20 mbar, 30 mbar

flue types: B23, B53, B53P, C13, C33, C53, C63 according to installation manual with flue system of Fa. Muelink & Grol (0432-BPR-220556), Centrotec (0036 CPD 9169 003), Tecnocontrol S. A (0063-CPD7990/2) and Groppalli (2592-CPR-0001)

