

EU TYPE-EXAMINATION CERTIFICATE (MODULE B) REGULATION (EU) 2016/426

This is to certify that the appliances listed have been examined and found to comply with the essential requirements listed in the **Regulation (EU) 2016/426** of the European Parliament and of the council of 9 March 2016 on appliances burning gaseous fuels (Annex I).

To demonstrate full compliance with the Regulation (EU) 2016/426, a "Conformity to Type" Module C2 or D or E or F is required.

Applicant: Riello S.p.A.
Via Ing. Pilade Riello, 7- 37045 (VR) - Italy
Trade Mark: BERETTA
Product Type: Central heating combi condensing boiler
Models: CIAO AT 25C
Certificate N°: ITS-2575-GAR-3416602
PIN: 2575DN34166

This certificate only relates to those products detailed in the following Test Reports:

Report Number: 200034166UDI-GCE-RCE

Certificate Issue date:

01 September 2022

Certificate Expiry date:

31 August 2032



Michael Albert Gandin

Certification Manager
Intertek Italia SpA (NB 2575)



PRD N° 277B

Membro degli Accordi di Mutuo
Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

PRODUCT DESCRIPTION

PRODUCT TYPE:	Central heating combi condensing boiler
MODELS:	CIAO AT 25C
STANDARD(S):	EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016
SPECIAL REMARKS:	Minimum ambient temperature = -10°C
APPLIANCES TYPE:	B _{22P} , B _{52P} , C ₁₂ , C ₃₂ , C ₄₂ , C ₅₂ , C ₆₂ , C ₈₂ , C ₉₂ , C _{12X} , C _{32X} , C _{42X} , C _{52X} , C _{62X} , C _{82X} , C _{92X}

The gas categories for which the appliances have been tested can be obtained by combining the following countries and gas groups:

COUNTRIES: AL, AT, BG, CH, CY, CZ, DE, DK, EE, ES, FI, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

GAS GROUP, REFERENCE GAS AND SUPPLY PRESSURES:

GROUP	REFERENCE GAS	GROUP	REFERENCE GAS	GROUP	REFERENCE GAS
H	G20 – 20 mbar	P	G31 – 30 mbar	P	G31 – 50 mbar
E	G20 – 20 mbar	P	G31 – 37 mbar		
H	G20 – 25 mbar				

REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PROJECT NO.	REPORT NO.	REASON FOR REVISION
01/09/2022	M.A. Gandin	34166	200034166UDI-GCE-RCE	R0: First issue

EC TYPE-EXAMINATION CERTIFICATE (MODULE B) DIRECTIVE 92/42/EEC

This is to certify that, with reference to the Council **Directive 92/42/EEC** of 21 May 1992 on efficiency requirements for new hot-water boilers fired with liquid or gaseous fuels and according to article 4 of commission regulation (EU) No. 813/2013, the appliances listed have achieved the full and part load efficiencies written on Annex 1.

To demonstrate full compliance with the Directive 92/42/EEC, a "Conformity to type" Module C or D or E is required.

Applicant: Riello S.p.A.
Via Ing. Pilade Riello, 7- 37045 (VR) - Italy

Trade Mark: BERETTA

Product Type: Central heating combi condensing boiler

Models: CIAO AT 25C

Certificate N°: ITS-2575-BED-3416602

PIN: 2575DN34166

Standard(s): EN 15502-1:012 + A1:2015, EN 15502-2-1:2012 + A1:2016

This certificate only relates to those products detailed in the following Test Reports:

Report Number: 200034166UDI-GCE-RCE

Certificate Issue date:

01 September 2022

Certificate Expiry date:

31 August 2032


Michael Albert Gandin

Certification Manager
Intertek Italia SpA (NB 2575)



PRD N° 277B

Membro degli Accordi di Mutuo
Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

ANNEX 1

Models:			
	CIAO AT 25C		
η_{100}	95,6 %		
η_{30}	101,7 %		
η_4	86,1 %		
η_1	91,6 %		
P_4	24,0 kW		
P_1	7,6 kW		
Combi Heater?	Yes		
B1 Boiler?	No		
Type of boiler:	Condensing		

Note: η_{100} = At rated heat output and high-temperature regime - NCV (*) - EN15502-1 clause 9.5.2.1: "the useful efficiency at nominal heat input Q_n or for range rated boilers at the arithmetic mean of the maximum and minimum heat input Q_a "
 η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**) - EN15502-1 clause 9.5.2.1: "the useful efficiency at 30 % of the nominal heat input Q_n or for range rated boilers at 30 % of the arithmetic mean of the maximum and minimum heat input Q_a "
 η_4 = At rated heat output and high-temperature regime (*)
 η_1 = At 30 % of rated heat output and low-temperature regime (**)
 P_4 = At rated heat output and high-temperature regime (*)
 P_1 = At 30 % of rated heat output and low-temperature regime (**)
 C.Heater = Combination Heater (Yes = with domestic hot water production / No = Heating system only)
 B1 Boiler = B1 according CEN/TR 1749:2014
 Type of boiler: "Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
 (**) Low temp. means for condensing boilers 30 °C, for low-temp. boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(n.t. = not tested; n.a. = not applicable)

REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PROJECT NO.	REPORT NO.	REASON FOR REVISION
01/09/2022	M.A. Gandin	34166	200034166UDI-GCE-RCE	R0: First issue